

Approval Number 260555059
Test Report: J-00525561, J-00552313 & RI0078/2/Op



27th August 2026

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10,
A - 2352 Gumpoldskirchen,
Austria

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE)- MATERIAL ONLY.

5295

'KLINGER®top-chem 2005'. Red coloured, PTFE based gasket material manufactured by calendering. For use with water up to 23°C.

APPROVAL NUMBER: 260555059

APPROVAL HOLDER: RICH. KLINGER DICHUNGSTECHNIK GMBH & CO. KG

The Scheme reserves the right to review approval.

Approval 260555059 is valid between May 2026 and May 2031

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager